New Division Electric

The Professional PAT Testing Company
Established: 2008

www.newdivisionelectric.co.uk
TEL: 01403 336399

- **Fully qualified & trained PAT operatives**
- **Quality assured inspections**
- **Fast turn around with certifications**

Client:	Orchard Property Maintenance	**Recommended Test Period:**	12 months
Address Line 1:	Unit 10, Grange Farm, Turners Hill Road,	**PAT Operatives:**	P.Savery
Address Line 2:	Crawley Down, RH10 4EY		
Customer ID:	RH045		
Completion Date	04/03/2026	**Signature:**	
Total Number of Tests:	51		
Microwave Emissions:	0		
P2P Fixed Wire Test:	0		
Total Passed:	51	**Name:**	Paul Savery
Total Failed:	0	**Title:**	Managing Director
Testing Period:	04/03/2026		

Location	Asset Number	Asset Description	Additional Info	Status	Voltage	EB Result	IR Result	IEC Wiring
OFFICE	56010	HEATER		PASS	Voltage: 230V	0.07	>19.99	
OFFICE	56011	HEATER		PASS	Voltage: 230V	0.11	>19.99	
OFFICE	56012	JETWASH		PASS	Voltage: 230V		>19.99	
OFFICE	56013	TRANSFORMER		PASS	Voltage: 230V	0.06	>19.99	
OFFICE	56014	PUMP		PASS	Voltage: 230V		>19.99	
OFFICE	56015	JETWASH		PASS	Voltage: 230V		>19.99	
OFFICE	56016	VACUUM CLEANER		PASS	Voltage: 230V		>19.99	

OFFICE	56017	DEHUMIDIFIER	PASS	Voltage: 230V		>19.99	
OFFICE	56018	DEHUMIDIFIER	PASS	Voltage: 230V		>19.99	
OFFICE	56019	DEHUMIDIFIER	PASS	Voltage: 230V		>19.99	
OFFICE	56020	VACUUM CLEANER	PASS	Voltage: 230V		>19.99	
OFFICE	56021	VACUUM CLEANER	PASS	Voltage: 230V		>19.99	
OFFICE	56022	DEHUMIDIFIER	PASS	Voltage: 230V		>19.99	
OFFICE	56023	DEHUMIDIFIER	PASS	Voltage: 230V		>19.99	
OFFICE	56024	DEHUMIDIFIER	PASS	Voltage: 230V	0.14	>19.99	
OFFICE	56025	VACUUM CLEANER	PASS	Voltage: 230V		>19.99	
OFFICE	56026	WELDER	PASS	Voltage: 230V	0.17	>19.99	
OFFICE	56027	CHARGER	PASS	Voltage: 230V		>19.99	
OFFICE	56028	EXTENSION	PASS	Voltage: 230V	0.82	>19.99	Good
OFFICE	56029	SANDER	PASS	Voltage: 230V		>19.99	
OFFICE	56030	EXTENSION	PASS	Voltage: 230V	0.28	>19.99	Good
OFFICE	56031	CHARGER	PASS	Voltage: 230V		>19.99	
OFFICE	56032	CHARGER	PASS	Voltage: 230V		>19.99	
OFFICE	56033	CHARGER	PASS	Voltage: 230V		>19.99	
OFFICE	56034	CHARGER	PASS	Voltage: 230V		>19.99	
OFFICE	56035	HEAT GUN	PASS	Voltage: 230V		>19.99	
OFFICE	56036	VACUUM CLEANER	PASS	Voltage: 230V		>19.99	
OFFICE	56037	VACUUM CLEANER	PASS	Voltage: 230V		>19.99	
OFFICE	56038	AC ADAPTER	PASS	Voltage: 230V		>19.99	
OFFICE	56039	HAMMER DRILL	PASS	Voltage: 230V		>19.99	
OFFICE	56040	MULTI TOOL	PASS	Voltage: 230V		>19.99	
OFFICE	56041	GRINDER	PASS	Voltage: 230V		>19.99	
OFFICE	56042	EXTENSION	PASS	Voltage: 230V	0.56	>19.99	Good
OFFICE	56043	GUTTER CLEANER	PASS	Voltage: 230V		>19.99	
OFFICE	56044	EXTENSION	PASS	Voltage: 230V	0.52	>19.99	Good
OFFICE	56045	EXTENSION	PASS	Voltage: 230V	0.52	>19.99	Good
OFFICE	56046	HAMMER DRILL	PASS	Voltage: 230V		>19.99	
OFFICE	56047	CHARGER	PASS	Voltage: 230V		>19.99	
OFFICE	56048	HAMMER DRILL	PASS	Voltage: 230V		>19.99	
OFFICE	56049	TRANSFORMER	PASS	Voltage: 230V	0.06	>19.99	

OFFICE	56050	HEAT GUN	PASS	Voltage: 230V		>19.99	
OFFICE	56051	VACUUM CLEANER	PASS	Voltage: 230V		>19.99	
OFFICE	56052	HAMMER DRILL	PASS	Voltage: 230V		>19.99	
OFFICE	56053	CHARGER	PASS	Voltage: 230V		>19.99	
OFFICE	56054	EXTENSION	PASS	Voltage: 230V	0.23	>19.99	Good
OFFICE	56055	CHARGER	PASS	Voltage: 230V		>19.99	
OFFICE	56056	CHARGER	PASS	Voltage: 230V		>19.99	
OFFICE	56057	CHARGER	PASS	Voltage: 230V		>19.99	
OFFICE	56058	CHARGER	PASS	Voltage: 230V		>19.99	
OFFICE	56059	CHARGER	PASS	Voltage: 230V		>19.99	
OFFICE	56060	CHARGER	PASS	Voltage: 230V		>19.99	
TOTAL: 51							